



MILAN

IL1610400

Annual Water Quality Report for the period of January 1 to December 31, 2016

This report is intended to provide you with important information about your drinking water and the efforts made by the MILAN water system to provide safe drinking water.

The source of drinking water used by MILAN is Ground Water.

For more information regarding this report contact:

Name: Kevin Farrell, Water – Sewer Superintendent

Phone: 309-787-8500

To be informed of the policy decisions affecting the operation of the water utility, please monitor the Milan Village Board Agenda. Agendas are posted at the Milan Municipal Building at least 48 hours prior to each Village Board meeting. Meetings are conducted on the first and third Monday of each month at 5:30 p.m. at the Municipal Building at 405 East 1st Street

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.



Village of Milan Annual Water Quality Report

Source of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Village of Milan Annual Water Quality Report January 1 to December 31, 2016

This year, as in years past, your tap water met all USEPA and IEPA drinking water health standards. Our system vigilantly safeguards its groundwater supply by performing over 3,000 chemical and bacteriological tests throughout the year. We are able to report that the department had no violation of a contaminant level or of any other water quality standard in the previous year. This report summarizes the quality of water that we provided last year, including details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies.

We are committed to providing you with this information because informed customers are our best allies.

Please note Milan Water department has received notification from the Illinois Department of Public Health of a Fluoridation Award for 10 consecutive years of maintaining perfect compliance. The Department acknowledges “achieving the highest standard of compliance” in maintaining proper Fluoride levels in the drinking water. Note also that we did not need to utilize the Rock Island water supply for our drinking water requirements this year.

Source Water Assessment

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings. The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by City Hall or call our water operator at 309-787-8500. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

Source of Water: To determine Milan's susceptibility to groundwater contamination, information obtained during a Well Site Survey performed by the Illinois Rural Water Association on April 26, 1999 was reviewed. Based on this information, five potential sites of concern were identified within proximity of this water supply's wells. The Illinois EPA does not consider the city's source water susceptible to contamination. This determination is based on a number of criteria including: monitoring conducted at the wells; monitoring conducted at the entry point to the distribution system; and the available hydrogeologic data on the wells.

Milan 2016 Regulated Contaminants Detected IL1610400

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALG's allow for a margin of safety.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Date Sampled: July-August 2016

Lead MCLG	Lead Action Level (AL)	Lead 90th Percentile	# Sites Over Lead AL	Copper MCLG	Copper Action Level (AL)	Copper 90th Percentile	# Sites Over Copper AL	Violation	Likely Source of Contamination
0	15 ppb	2.0 ppb	0	1.3 ppm	1.3 ppm	0.46 ppm	0	N	Lead: Corrosion of household plumbing systems; Erosion of natural deposits Copper: Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing

Water Quality Test Results

Definitions: The following tables contain scientific terms and measures, some of which may require explanation.

-Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health.

MCLG's allow for a margin of safety.

-Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the Maximum Contaminant Level Goal as feasible using the best available treatment technology.

-Maximum Residual Disinfectant Level Goal (MRDLG): The level of disinfectant in drinking water below which there is no known or expected risk to health. MRDLG's allow for a margin of safety.

-Maximum Residual Disinfectant Level (MRDL): The highest level of disinfectant allowed in drinking water.

ppm: - parts per million or mg/l: milligrams per liter - or one ounce in 7,350 gallons of water.

ppb: - parts per billion or ug/l: micrograms per liter - or one ounce in 7,350,000 gallons of water. na: not applicable.

Avg: -Regulatory compliance with some MCLs is based on running annual average of monthly samples.

na: -not applicable

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Samples	Violations	Likely Source of Contaminant
0	1 positive monthly sample	2		0	No	Naturally present in the environment

Regulated Contaminants

Disinfectants & Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source Of Contaminant
Chlorine	12/31/2016	1.7	11 – 2.4	MRDLG=4	MRDL=4	ppm	No	Water additive used to control microbes
Haloacetic Acids (HAA5)	2016	2	2.33 – 2.33	No Goal for the total	60	ppb	No	By-product of drinking water chlorination
Total Trihalomethanes (TTHM)	2013	3.047	3.047 – 3.047	No Goal for the total	80	ppb	No	By-product of drinking water chlorination

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source Of Contaminant
Arsenic	1/27/2014	3	0 – 3	0	10	ppb	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	1/27/2014	0.56	0.25 – 0.56	2	2	ppm	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium	1/27/2014	4.8	0 – 4.8	100	100	ppb	No	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride	2016	1.1	1.1 – 1.1	4	4.0	ppm	No	Erosion of natural deposits; Water additive which promotes strong teeth; Fertilizer discharge
Iron	1/27/2014	0.17	0.12 – 0.17		1.0	ppm	No	Erosion from naturally occurring deposits
Manganese	1/27/2014	37	3.6 – 37	150	150	ppb	No	Erosion from naturally occurring deposits
Nitrate (As Nitrogen)	2016	0.08	0.03 – 0.08	10	10	ppm	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium	1/27/2014	8.4	0 – 8.4	50	50	ppb	No	Erosion of natural deposits
Sodium	1/27/2014	270	43 – 270			ppm	No	Erosion of naturally occurring deposits; used in water softener regeneration
Zinc	2/8/11	0.006	0.006 – 0.006	5	5	ppm	No	Discharge from petroleum and metal refineries; Erosion of natural deposits

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source Of Contaminant
Combined Radium 226/228	1/6/2015	1.69	1.69 – 1.69	0	5	pCi/L	No	Erosion of natural deposits
Gross Radium excluding radon and uranium	1/6/2015	4.55	4.55 – 4.55	0	15	pCi/L	No	Erosion of natural deposits

Violations Table

Milan Public Water Supply did not receive any violations for 2016
--

Village of Milan
405 East 1st Street
Milan, IL 61264

PRESRT STD
US POSTAGE
PAID
MILAN, IL 61264
PERMIT NO 57

Current Resident or